

SYSTEM SUPPLIER CERTIFICATE OF APPROVAL No CS 5127

This is to certify that, in accordance with
STS200 General Requirements for Certification of Enhanced Security Products
The undermentioned products of

SAINT-GOBAIN CONSTRUCTION PRODUCTS UK LIMITED TRADING AS BRITISH GYPSUM

British Gypsum Head Office, East Leake,
Loughborough, Leicestershire, LE12 6JU
Tel: 0115 9451000

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT	TECHNICAL SCHEDULE
British Gypsum GypWall Quiet L216002 and British Gypsum GypWall Quiet IWL L216009, L216010	STS202 - Requirements for burglary resistance of construction products

This specification document relates to the design of the non-loadbearing partition system only
and does not allow installation and on-site build of the product to demonstrate compliance with
CERTISECURE, STS202 or Secured by Design.

CLASSIFICATION
Security
STS202 BR1

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

Paul Duggan
Certification Manager



Issued: 19th August 2021
Audit Test Frequency: Annually
Valid to: 18th August 2026



CERTIFICATE No CS 5127

SAINT-GOBAIN CONSTRUCTION PRODUCTS UK LIMITED TRADING AS BRITISH GYPSUM

**Saint-Gobain Construction Products UK Limited Trading As British Gypsum –
British Gypsum GypWall Quiet L216002 and British Gypsum GypWall Quiet
IWL L216009, L216010**

1. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
2. This approval relates to the design of the non-loadbearing partition system only. The approval does not cover installation and on-site build of the product. Installation of the product is outside of the scope of this certification.
3. This approval relates to the use of the above in providing a burglar resistance to STS 202: Issue 9: October 2020 level BR1.
4. The non-loadbearing partitions system design is approved on the basis of:
 - i. Initial type testing against STS202. Element Wednesbury test reports WIL 392361, WIL 400604 & WIL 402385.
 - ii. Audit testing at the frequency specified in STS200 & 202 where relevant.
 - iii. A design appraisal against STS202 where relevant.
 - iv. Inspection and surveillance of the processes related to the design and control of the product at British Gypsum Head Office, East Leake, Loughborough, Leicestershire, LE12 6HX
5. This approval is applicable to complete non-loadbearing partitions only.
6. This certification is designed to demonstrate compliance of the non-loadbearing partitions specifically with STS202 and the requirements of Secured by Design. If compliance is required to other regulatory or guidance documents there may be additional considerations or conflict to be taken into account.
7. This approval is applicable to non-loadbearing partitions at dimensions given in Table 1.

For the full specification of the product please refer to the constructional specification that accompanies this certificate.



CERTIFICATE No CS 5127
SAINT-GOBAIN CONSTRUCTION
PRODUCTS UK LIMITED TRADING
AS BRITISH GYPSUM

Saint-Gobain Construction Products UK Limited Trading As British Gypsum –
British Gypsum GypWall Quiet L216002 and British Gypsum GypWall Quiet
IWL L216009, L216010

Configuration	Maximum stud centres (mm)	Maximum partition height (mm)	Minimum partition thickness (mm)
GypWall QUIET L216002	600 *	4000	195
GypWall QUIET IWL L216009	600 *	3300	225
GypWall QUIET IWL L216010	600 *	3600	225

* Multiples of this maximum stud width jointed in accordance with the constructional specification to form a continuous partition can be considered to be within the scope of this certificate.

Table 1. Permitted Dimensions

8. The non-loadbearing partitions shall be mechanically fixed as described in manufacturers approved installation instructions.

Further Information

Further information regarding the details contained in this report may be obtained from British Gypsum, East Leake, Loughborough, Leicestershire, LE12 6HX (Email: BGTechnical.Enquiries@bpb.com).

Further information regarding CERTISECURE certification and other approved products can be obtained from Warringtonfire Testing & Certification Limited, Holmesfield Road, Warrington WA1 2DS

