

UL INTERNATIONAL (UK) LTD  
 Kingsland Business Park,  
 Unit 1-3 Horizon,  
 Wade Rd,  
 Basingstoke RG24 8AH,  
 United Kingdom

appointed according to Article 29 of Construction Products Regulation 2011 as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020

<b>UK Technical Assessment</b>	<b>0843-UKTA-25/0023 of 28/11/2025</b>
--------------------------------	--------------------------------------------

<b>Technical Assessment Body Issuing the UKTA:</b>	UL International (UK) Ltd
<b>Trade name of the construction product</b>	Gyproc Fire Coating
<b>Product family to which the construction product belongs</b>	Fire Stopping and Sealing Product: <ul style="list-style-type: none"> <li>• Linear Joint and Gap Seals</li> </ul>
<b>Manufacturer</b>	Saint-Gobain Construction Products UK Ltd t/a British Gypsum Saint-Gobain House, East Leake, Loughborough, Leicestershire, LE12 6JU
<b>Manufacturing plant(s)</b>	A/003
<b>This UK Technical Assessment contains</b>	11 pages including 1 Annex which forms an integral part of this assessment.
<b>This UK Technical Assessment* is issued, on the basis of</b>	EAD 350141-00-1106, September 2017.
<b>This version replaces</b>	0843-UKTA-25/0023 issued 30/05/2025

Translations of this UK Technical Assessment in other languages shall fully correspond to the original issued document and should be identified as such.

Communication of this UK Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may be made, with the written consent of the issuing Technical Assessment Body. Any partial reproduction shall be identified as such.

\* in accordance with Construction Products Regulation 2011 as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020

**Table of Contents**

**I. SPECIFIC PARTS OF THE UK TECHNICAL ASSESSMENT ..... 3**

1 Technical description of the product .....3

2 Specification of the intended uses of the product in accordance with the applicable UK Assessment Document (Pre-Exit European Assessment Document): EAD 350141-00-1106: 2017 .....3

3 Performance of the product and references to the methods used for its assessment .....5

4 ASSESSMENT AND VERIFICATION OF CONSTANCY OF PERFORMANCE (HEREINAFTER AVCP) SYSTEM APPLIED, WITH REFERENCE TO ITS LEGAL BASE .....6

5 Technical details necessary for the implementation of the AVCP system, as provided for in the applicable EAD .....6

6 Issued on: .....7

**ANNEX A – Resistance to Fire Classification – Gyproc Fire Coating ..... 8**

A.1 Rigid floor constructions with thickness of minimum 150 mm .....8

A.1.2 Linear joints in a horizontal construction, horizontal linear joints in a vertical construction and horizontal floor joints abutting a wall..9

A.1.3 Linear joints in a vertical construction and horizontal wall joints abutting a floor, ceiling or roof .....10

**ANNEX B – Air Permeability – Gyproc Fire Batt ..... 11**

## I. SPECIFIC PARTS OF THE UK TECHNICAL ASSESSMENT

### 1 Technical description of the product

- 1) Gyproc Fire Coating is an ablative sealant coating designed to enhance, seal and fire protect mineral fibres. It is based on a durable polymer system with inert fillers, non-halogenated fire retardants and a preservative to resist microbial attack. Gyproc Fire Coating is a sprayed coating product that is site or factory applied to both faces of a stone wool, mineral fibre board or site applied to one face of stone wool mineral fibre backer, to form a linear joint seal system. The intended use of Gyproc Fire Coating is to reinstate the fire resistance performance of floor to floor/ floor to wall joints and wall gaps. Typical locations of linear joints include floors, the perimeter of floors, walls, ceilings and roofs.
- 2) The Gyproc Fire Coating system, when factory applied/supplied is referenced Gyproc Fire Batt.
- 3) The Gyproc Fire Coating may be applied to stone wool or ceramic wool with a density minimum 33 kg/m<sup>3</sup>, with minimum 1.0 mm WFT (see annex A for details).
- 4) Applicant has submitted a written declaration that Gyproc Fire Coating does not contain substances which have to be classified as dangerous according to Directive 67/548/EEC and Regulation (EC) No 1272/2008 and listed in the "Indicative list on dangerous substances" of the EGDS - taking into account the installation conditions of the construction product and the release scenarios resulting from there.

In addition to the specific clauses relating to dangerous substances contained in this European technical Assessment, there may be other requirements applicable to the products falling within its scope (e.g. transposed European legislation and national laws, regulations and administrative provisions). In order to meet the provisions of the Construction Products Regulation, these requirements need also to be complied with, when and where they apply.

- 5) The use category of Gyproc Fire Coating in relation to BWR 3 (Hygiene, health and environment) is IA1, S/W2

### 2 Specification of the intended uses of the product in accordance with the applicable UK Assessment Document (Pre-Exit European Assessment Document): EAD 350141-00-1106: 2017

Detailed information and data is given in Annex A.

- 1) The intended use of Gyproc Fire Coating is to reinstate the fire resistance performance of gaps in and joints between rigid floors and between rigid floors and rigid wall constructions, gaps in and joints between rigid floor constructions.
- 2) The specific elements of construction that the system Gyproc Fire Coating may be used to provide a linear joint or gap seal in, are as follows:
  - c. Rigid floors: The floor must have a minimum thickness of 150 mm and comprise aerated concrete, concrete, blockwork or masonry with a minimum density of 650 kg/m<sup>3</sup>.
  - d. Rigid walls: The wall must have a minimum thickness of 150 mm and comprise concrete, aerated concrete blockwork or masonry, with a minimum density of 650 kg/m<sup>3</sup>.

The supporting construction must be classified in accordance with EN 13501-2 for the required fire resistance period. (for details see Annex A)

- 3) The system Gyproc Fire Coating may be used to provide a linear joint or gap seal with specific supporting constructions and substrates (for details see Annex A).
- 4) The maximum permitted joint/gap width for system Gyproc Fire Coating is 600 mm.
- 5) The maximum movement capability of system Gyproc Fire Batt is  $\leq 7.5\%$
- 6) Precautions are required to be taken to prevent a person stepping onto a horizontal linear joint seal or falling against a vertical, or sloped, linear joint seal.
- 7) The provisions made in this UK Technical Assessment are based on an assumed working life of the Gyproc Fire Coating of 25 years, provided that the conditions laid down in the product datasheet for the packaging/transport/ storage/installation/use/repair are met. The indications given on the working life cannot be interpreted as a guarantee given by the producer, or the Technical Assessment Body but are to be regarded only as a means of choosing the right products in relation to the expected economically reasonable working life of the works.
- 8) Use category: Type Y<sub>1</sub>: Intended for use at temperatures below 0°C with exposure to UV but no exposure to rain. Includes lower classes Y<sub>2</sub>, Z<sub>1</sub>, Z<sub>2</sub>.

### 3 Performance of the product and references to the methods used for its assessment

Product-type: Coating		Intended use: Linear Joint & Gap Seal
Basic requirement for construction work	Essential characteristic	Performance
<b>BWR 2 Safety in case of fire</b>		
EN 13501-1	Reaction to fire	D – s1, d0
EN 13501-2	Resistance to fire	Annex A
<b>BWR 3 Hygiene, health and environment</b>		
Declaration of manufacturer & EN 16516	Content, emission and/or release of dangerous substances	Use categories: IA1, S/W2 Declaration of manufacturer
EN 1026:2000	Air permeability (material property)	Annex B
EAD 350141-00-1106, Annex C & EN 12390-8	Water permeability (material property)	No performance determined
<b>BWR 4 Safety in use</b>		
EOTA TR 001:2003	Mechanical resistance and stability	No performance determined
EOTA TR 001:2003	Resistance to impact/movement	No performance determined
EOTA TR 001:2003 ISO 11600 & EAD 350141-00-1106, Clause 2.2.13	Adhesion	No performance determined
EAD 350141-00-1106, Clause 2.2.12	Durability	Y <sub>1</sub>
EAD 350141-00-1106, Clause 2.2.13	Movement capacity	No performance determined
EAD 350141-00-1106, Clause 2.2.14	Cycling of perimeter seals for curtain walls	No performance determined
EAD 350141-00-1106, Clause 2.2.15	Compression set	No performance determined
EAD 350141-00-1106, Clause 2.2.16	Linear expansion on setting	No performance determined
<b>BWR 5 Protection against noise</b>		
EN 10140-1,2,4,5/ EN ISO 717-1	Airborne sound insulation	No performance determined
<b>BWR 6 Energy economy and heat retention</b>		
EN 12664, EN 12667, EN 12939, EN ISO 8990, EN ISO 6946, EN ISO 10456	Thermal properties	No performance determined
EN ISO 12572, EN 12086, EN ISO 10456	Water vapour permeability	No performance determined

**4 ASSESSMENT AND VERIFICATION OF CONSTANCY OF PERFORMANCE (HEREINAFTER AVCP) SYSTEM APPLIED, WITH REFERENCE TO ITS LEGAL BASE**

According to the Statutory Instrument 2019 No. 465 – made 5<sup>th</sup> March 2019 and cited as the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and coming into force on exit day and Statutory Instrument 2020 No. 1359 – made 26<sup>th</sup> November 2020 and cited as the Construction Products (Amendment etc.) (EU Exit) Regulations 2020 and coming into force immediately before the 2019 Regulations come into force, on the procedure for attesting the conformity of construction products as regards fire stopping, fire sealing and fire protective products, published as ‘Pre-Exit’ European Assessment Documents, (see <https://www.gov.uk/guidance/pre-exit-european-assessment-documents-construction-products>), the system of assessment and verification of constancy of performance (see Annex V to Construction Products Regulation 2011 as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020) given in the following table(s) apply.

<b>Product(s)</b>	<b>Intended use(s)</b>	<b>Level(s) or class(es)</b>	<b>System(s)</b>
Fire stopping and Fire Sealing Products	For fire compartmentation and/or fire protection or fire performance	Any	1

**5 Technical details necessary for the implementation of the AVCP system, as provided for in the applicable EAD**

**Tasks of the manufacturer:**

Factory production control

The manufacturer shall exercise permanent internal control of production. All the elements, requirements and provisions adopted by the manufacturer shall be documented in a systematic manner in the form of written policies and procedures, including records of results performed. This production control system shall ensure that the product is in conformity with this UK Technical Assessment.

The factory production control shall be in accordance with the Control Plan of FPC 25th June 2024 relating to the UK Technical Assessment 0843-UKTA-25/0023 issued on 28/11/2025 which is part of the technical documentation of this UK technical Assessment. The "Control Plan" is laid down in the context of the factory production control system operated by the manufacturer and deposited at UL International (UK) Ltd.

The results of factory production control shall be recorded and evaluated in accordance with the provisions of the Control Plan.

**Other tasks of the manufacturer:**

Additional information

The manufacturer shall provide a technical data sheet and an installation instruction with the following minimum information:

(a) Technical data sheet:

- Field of application
- Building elements for which the perimeter seal is suitable, type and properties of the building elements like minimum thickness, density, and - in case of lightweight constructions – the construction requirements
- Limits in size, minimum thickness etc. of the perimeter seal
- Construction of the perimeter seal including the necessary components and additional products (e.g. backfilling material) with clear indication whether they are generic or specific.

(b) Installation instruction:

- Steps to be followed
- Procedure in case of retrofitting
- Stipulations on maintenance, repair and replacement

**6 Issued on:**

**28<sup>th</sup> November 2025**

Report by:



P. Foster  
Project Engineer Associate  
Built Environment

Reviewed by:




D. Forshaw  
Staff Engineer  
Built Environment

**For and on behalf of UL International (UK) Ltd.**

# ANNEX A – Resistance to Fire Classification – Gyproc Fire Coating

## A.1 Rigid floor constructions with thickness of minimum 150 mm

### A.1.1 Linear joints in a horizontal construction, horizontal linear joints in a vertical construction and horizontal floor joints abutting a wall



#### A.1.1.1

Substrate	Depth (mm)	Backing	Classification *
masonry/ concrete	1 mm WFT min. both sides with Gyproc Fire Coating. Sealed at the joint and along the top and bottom edges with Gyproc Acrylic Fire Sealant	60 mm stone wool, mineral fibre batt min. 160 kg/m <sup>3</sup> at any position	<b>E 240 – H – X – F – W120</b> <b>EI 120 – H – X – F – W120</b>
masonry/ concrete/ aluminium	1 mm WFT min. both sides with Gyproc Fire Coating. Sealed at the joint and along the edges on the top and bottom edges with Gyproc Acrylic Fire Sealant	60 mm stone wool, mineral fibre batt min. 160 kg/m <sup>3</sup> at any position	<b>E 120 – H – X – F – W0</b> <b>EI 60 – H – X – F – W0<sup>1</sup></b>
masonry/ concrete/ aluminium/ steel		60 mm stone wool, mineral fibre batt min. 160 kg/m <sup>3</sup> top face position	<b>E 120 – H – X – F – W600</b> <b>(For EI performance recorded on the seal only, please see note<sup>2</sup> below)</b>


\*Additional and for information only.

The classifications provided in Table A.1.1.1 consider the insulation performance of all components within the firestopping system as per the requirements of EN 1366-4. This includes temperature evaluation of the metal substrates.

In relation to each of the above classifications, temperatures recorded on the seal (exclusive of the supporting construction) exceeded the maximum allowable after the following times (rounded down):

<sup>1</sup> 90, <sup>2</sup> 120

**A.1.2 Linear joints in a horizontal construction, horizontal linear joints in a vertical construction and horizontal floor joints abutting a wall**



**A.1.2.1**

Substrate	Depth (mm)	Backing	Classification *
masonry/ concrete	1 mm WFT min. top face	100 mm stone wool, mineral fibre min. 33 kg/m <sup>3</sup>	<b>E 240 – H – X – F – W120</b> <b>EI 180 – H – X – F – W120</b>
masonry/ concrete	1.2 mm WFT min. top face	100 mm stone wool, mineral fibre min. 80 kg/m <sup>3</sup> , compressed into gap by 20%	<b>E 240 – H – X – F – W200</b> <b>EI 240 – H – X – F – W200</b>
masonry/ concrete/ aluminium/ steel			<b>E 240 – H – X – F – W200</b> <b>EI 15 – H – X – F – W200 <sup>1</sup></b>

\*Additional and for information only.


The classifications provided in Table A.1.2.1 consider the insulation performance of all components within the firestopping system as per the requirements of EN 1366-4. This includes temperature evaluation of the metal substrates.

In relation to each of the above classifications, temperatures recorded on the seal (exclusive of the supporting construction) exceeded the maximum allowable after the following times (rounded down):

<sup>1</sup> 120

### A.1.3 Linear joints in a vertical construction and horizontal wall joints abutting a floor, ceiling or roof

**Joint Seal:** Mineral fibre insulation compression fitted to either face of the wall or at any position in between and coated with Gyproc Fire Coating



#### A.1.3.1

Substrate	Depth (mm)	Backing	Classification
masonry/ concrete	1.2 mm WFT min. both faces overlapped by 15 mm onto wall surface	100 mm stone wool, mineral fibre min. 35 kg/m <sup>3</sup> , compressed into gap by 40%	<b>E 240 – T – X – F – W120</b> <b>EI 180 – T – X – F – W120</b>
	1.2 mm WFT min. single sided overlapped by 15 mm onto wall surface	100 mm stone wool, mineral fibre min. 33 kg/m <sup>3</sup> , compressed into gap by 40%	<b>E 120 – T – X – F – W120</b> <b>EI – T – X – F – W120</b>
	1.2 mm WFT min. both faces overlapped by 15 mm onto wall surface	100 mm stone wool, mineral fibre min. 80 kg/m <sup>3</sup> , compressed into gap by 10%	<b>E 240 – V – X – F – W200</b> <b>EI 120 – V – X – F – W200</b>
	1.2 mm WFT min. single sided overlapped by 15 mm onto wall surface	100 mm stone wool, mineral fibre min. 80 kg/m <sup>3</sup> , compressed into gap by 10%	<b>E 180 – V – X – F – W200</b> <b>EI – V – X – F – W200</b>

## ANNEX B – Air Permeability – Gyproc Fire Batt

Product tested	1200mm high x 600mm wide Gyproc Fire Batt 50mm 2-S		
	Summary of testing procedure		Result
	Pressure (Pa)	Leakage (m <sup>3</sup> /h)	Leakage (m <sup>3</sup> /m <sup>2</sup> /h)
Results under negative chamber pressure	25	0.00	0.00
	50	0.01	0.01
	100	0.02	0.03
	200	0.04	0.06
	0	0.11	0.15
	450	0.49	0.68
	600	0.95	1.32
Results under positive chamber pressure	25	0.00	0.00
	50	0.01	0.01
	100	0.03	0.04
	200	0.08	0.11
	0	0.2	0.28
	450	0.63	0.88
	600	1.01	1.40

