Technical Specification


This document provides guidance on how to achieve performance and warranty requirements by exclusively using British Gypsum products or system specifications.



GypWall Single Frame

A206210 MR1 (EN)

Two layers of Gyproc SoundBloc 12.5mm one side and an inner layer of Gyproc SoundBloc 12.5mm and an outer layer of Gyproc SoundBloc MR 12.5mm the other side of Gypframe 146 S 50 'C' Studs at 600mm centres. 25mm Isover Acoustic Partition Roll (APR 1200) in the cavity. For heights up to 4000mm.



Head design

| Head channel | Gypframe 148 FEC 50 Folded Edge Standard Floor & Ceiling Channel | |
|---|--|--|
| Gypframe channel suitably fixed to soffit at 600mm centres in two lines staggered by 300mm. | | |
| Deflection allowance | Vertical deflection only. To be determined by a Structural Engineer. | |
| Dropped soffit For principles of deflection head construction refer to detail ST-121-Z1L2-08. | | |

Framework

| Stud | Gypframe 146 S 50 'C' Stud | |
|-------------------------|----------------------------|--|
| Stud centres - Max (mm) | 600 | |
| Abutments and openings | Gypframe 146 S 50 'C' Stud | |

Gypframe 'C' stud suitably fixed to structure at 600mm centres in two lines staggered by 300mm.

| Base channel | Gypframe 148 FEC 50 Folded Edge Standard Floor & Ceiling Channel |
|--------------|--|
|--------------|--|

Gypframe channel suitably fixed to floor at 600mm centres in two lines staggered by 300mm.

Insulation

| Insulation, Layer 1 | 25mm Isover Acoustic Partition Roll (APR 1200) |
|---------------------|--|
|---------------------|--|

Board and fixings

| Board side 1, Layer 1 | Gyproc SoundBloc 12.5mm | oroc SoundBloc 12.5mm Screws side 1, Layer 1 British Gypsum Drywall Screws 25mm | |
|-----------------------|---|---|------------------------------------|
| Board side 1, Layer 2 | Gyproc SoundBloc 12.5mm Screws side 1, Layer 2 British Gypsum Drywall Screws 35m | | British Gypsum Drywall Screws 35mm |
| Board side 2, Layer 1 | Gyproc SoundBloc 12.5mm Screws side 2, Layer 1 British Gypsum Drywall Screws 25mm | | British Gypsum Drywall Screws 25mm |
| Board side 2, Layer 2 | Gyproc SoundBloc MR 12.5mm | Screws side 2, Layer 2 | British Gypsum Drywall Screws 35mm |

Board layer 1 (inner), fix securely to Gypframe metal supports around the perimeter of the board at maximum 300mm centres; Board layer 2 (outer), fix securely to all Gypframe metal supports around the perimeter of the board and intermediate stud positions at maximum 300mm centres. External corners reduce fixings to 200mm. All joints staggered between layers. Fix working from the centre of each board. Position screws not less than 13mm from cut edges and 10mm from bound edges of boards. Set screw heads flush with plasterboard surface; do not break paper or gypsum core.

| Fixing strap | Gypframe GFS1 Fixing Strap |
|--------------|----------------------------|
| | |

Used to support horizontal board joints in face layer of multiple layer board linings and enable board screw fixing at 300mm centres.

| Sediani | Gyproc Sealant | | | | | |
|--------------------------------------|--------------------------------------|-------------------------------------|------------------------|-----------------|----------------------|-----------|
| Locate coalant at junctions with adi | cining structure and other air noths | Apply as a continuous boad to clean | dry dust free surfaces | leaving no gone | After application of | f coalant |

Locate sealant at junctions with adjoining structure and other air paths. Apply as a continuous bead to clean, dry, dust-free surfaces, leaving no gaps. After application of sealant, bulk fill gaps between floor and underside of plasterboard using Gyproc joint compound.

Finish coat

To achieve the specified performances, the system should be finished using either one of our Thistle or ThistlePro plasters, or Gyproc jointing products. See the product range guides on the British Gypsum website for more information. For further guidance on skimming moisture resistant grade boards see the White Book - Finishes section.

Technical Specification


This document provides guidance on how to achieve performance and warranty requirements by exclusively using British Gypsum products or system specifications.



GypWall Single Frame

A206210 MR1 (EN)

Two layers of Gyproc SoundBloc 12.5mm one side and an inner layer of Gyproc SoundBloc 12.5mm and an outer layer of Gyproc SoundBloc MR 12.5mm the other side of Gypframe 146 S 50 'C' Studs at 600mm centres. 25mm Isover Acoustic Partition Roll (APR 1200) in the cavity. For heights up to 4000mm.



System performance

Please read performance data with any associated standards.

| Fire integrity (mins) | 60 |
|-----------------------|------|
| Maximum height (mm) | 4000 |

| Fire insulation (mins) | 60 |
|------------------------|----|
| | |

The maximum heights quoted are limited by the fire state field of application or by limiting deflection of L/240 at 200 Pa, whichever is the lower of the two.

| Sound insulation (Airborne) Rw (dB) | 55 |
|-------------------------------------|--------|
| Duty rating | Severe |
| Partition thickness (mm) | 198 |
| Approx. weight (kg/m2) | 43 |

| Sound insulation (Airborne) Rw + Ctr (dB) | 49 |
|---|----|
|---|----|

Standards

These standards relate to the above performance data.

BS EN 1364-1, Fire resistance tests for non-loadbearing elements - Walls.

BS 5234-2, Specification for performance requirements for strength and robustness including methods of test.

BS EN ISO 140-3, Acoustics - Measurement of sound insulation in buildings and of building elements. Laboratory measurement of airborne sound insulation of building elements.

Further information

SpecSure® system performance warranty confirms that British Gypsum proprietary systems will perform as specified for the lifetime of the building. The SpecSure® warranty requires that all components are specified in full and constructed in accordance with British Gypsum's installation guidance. For more details see the British Gypsum website. Always check with the design team before making any changes to the chosen specification, ensuring appropriate substantiation is sought to confirm that the solution still meets all required project performances.

This Technical Specification stipulates all British Gypsum products used within a system. These must be used to achieve the stated performance and the **SpecSure®** system warranty.