


Technical Specification

This document provides guidance on how to achieve performance and warranty requirements by exclusively using British Gypsum products or system specifications.

GypWall Single Frame Enhanced

A206A277 (EN)

One layer of Gyproc DuraLine 15mm each side of Gypframe 92 AS 50 AcouStuds at 600mm centres. For heights up to 4000mm.



Head design

Head channel	Gypframe 94 DC 60 Deep Flange Floor & Ceiling Channel
Gypframe channel suitably fixed to soffit at 600mm centres in two lines staggered by 300mm.	
Deflection allowance	Vertical deflection only. To be determined by a Structural Engineer.
Dropped soffit	For principles of deflection head construction refer to detail ST-122-Z3L1-07.

Framework

Stud	Gypframe 92 AS 50 AcouStud
Stud centres - Max (mm)	600
Abutments and openings	Gypframe 92 S 60 'C' Stud
Gypframe 'C' stud suitably fixed to structure at 600mm centres in two lines staggered by 300mm.	
Base channel	Gypframe 94 DC 60 Deep Flange Floor & Ceiling Channel
Gypframe channel suitably fixed to floor at 600mm centres in two lines staggered by 300mm.	

Insulation

No insulation

Board and fixings

Board side 1, Layer 1	Gyproc DuraLine 15mm	Screws side 1, Layer 1	British Gypsum Drywall Screws 25mm
Board side 2, Layer 1	Gyproc DuraLine 15mm	Screws side 2, Layer 1	British Gypsum Drywall Screws 25mm
Board layer 1, fix securely to Gyframe metal supports around the perimeter of the board and intermediate stud positions at maximum 300mm centres. External corners reduce fixings to 200mm. All joints staggered between layers. Fix working from the centre of each board. Position screws not less than 13mm from cut edges and 10mm from bound edges of boards. Set screw heads flush with plasterboard surface; do not break paper or gypsum core.			
Fixing strap	Gypframe GFS1 Fixing Strap		
Used to support horizontal board joints and enable board screw fixing at 300mm centres.			
Fixing T	Gypframe GFT1 Fixing 'T'		
Used to support horizontal board joints and enable board screw fixing at 300mm centres.			
Sealant	Gyproc Sealant		
Locate sealant at junctions with adjoining structure and other air paths. Apply as a continuous bead to clean, dry, dust-free surfaces, leaving no gaps. After application of sealant, bulk fill gaps between floor and underside of plasterboard using Gyproc joint compound.			

Finish coat

To achieve the specified performances, the system should be finished using either one of our Thistle or ThistlePro plasters, or Gyproc jointing products. See the product range guides on the British Gypsum website for more information.


Technical Specification

This document provides guidance on how to achieve performance and warranty requirements by exclusively using British Gypsum products or system specifications.

GypWall Single Frame Enhanced

A206A277 (EN)

One layer of Gyproc DuraLine 15mm each side of Gypframe 92 AS 50 AcouStuds at 600mm centres.
For heights up to 4000mm.



System performance

Please read performance data with any associated standards.

Fire integrity (mins)	60
Maximum height (mm)	4000

Fire insulation (mins)	60
------------------------	----

The maximum heights quoted are limited by the fire state field of application or by limiting deflection of L/240 at 200 Pa, whichever is the lower of the two.

Sound insulation (Airborne) Rw (dB)	45
Duty rating	Severe
Partition thickness (mm)	124
Approx. weight (kg/m ²)	29

Standards

These standards relate to the above performance data.

BS EN 1364-1, Fire resistance tests for non-loadbearing elements - Walls.

BS 5234-2, Specification for performance requirements for strength and robustness including methods of test.

BS EN ISO 140-3, Acoustics - Measurement of sound insulation in buildings and of building elements. Laboratory measurement of airborne sound insulation of building elements.

Further information

SpecSure® system performance warranty confirms that British Gypsum proprietary systems will perform as specified for the lifetime of the building. The **SpecSure®** warranty requires that all components are specified in full and constructed in accordance with British Gypsum's installation guidance. For more details see the British Gypsum website. Always check with the design team before making any changes to the chosen specification, ensuring appropriate substantiation is sought to confirm that the solution still meets all required project performances.