
# **Technical Specification**

This document provides guidance on how to achieve performance and warranty requirements by exclusively using British Gypsum products or system specifications.



### GypWall Single Frame A206A281 MR1 (EN)

One layer of Gyproc SoundBloc 15mm one side and one layer of Gyproc SoundBloc MR 15mm the other side of Gypframe 92 AS 50 AcouStuds at 600mm centres. For heights up to 4000mm.



## **Head design**

Head channel	Gypframe 94 FEC 50 Folded Edge Standard Floor & Ceiling Channel			
Gypframe channel suitably fixed to soffit at 600mm centres in two lines staggered by 300mm.				
Deflection allowance	Vertical deflection only. To be determined by a Structural Engineer.			
Dropped soffit	For principles of deflection head construction refer to detail ST-121-Z3L1-08.			

### Framework

Stud	Gypframe 92 AS 50 AcouStud			
Stud centres - Max (mm)	600			
Abutments and openings	Gypframe 92 S 50 'C' Stud			
Gypframe 'C' stud suitably fixed to structure at 600mm centres in two lines staggered by 300mm.				
Base channel	Gypframe 94 FEC 50 Folded Edge Standard Floor & Ceiling Channel			

Gypframe channel suitably fixed to floor at 600mm centres in two lines staggered by 300mm.

#### Insulation

No insulation

## **Board and fixings**

Board side 1, Layer 1	Gyproc SoundBloc 15mm	Screws side 1, Layer 1	British Gypsum Drywall Screws 25mm				
Board side 2, Layer 1	Gyproc SoundBloc MR 15mm	Screws side 2, Layer 1	British Gypsum Drywall Screws 25mm				
Board layer 1, fix securely to Gypframe metal supports around the perimeter of the board and intermediate stud positions at maximum 300mm centres. External corners reduce fixings to 200mm. All joints staggered between layers. Fix working from the centre of each board. Position screws not less than 13mm from cut edges and 10mm from bound edges of boards. Set screw heads flush with plasterboard surface; do not break paper or gypsum core.							
Fixing strap	Gypframe GFS1 Fixing Strap						
Used to support horizontal board joints and enable board screw fixing at 300mm centres.							
Fixing T	Gypframe GFT1 Fixing 'T'						
Used to support horizontal boar	d joints and enable board screw fixing at 300mm of	centres.					
Sealant	Gyproc Sealant						

Sealant Gyproc Sealant

Locate sealant at junctions with adjoining structure and other air paths. Apply as a continuous bead to clean, dry, dust-free surfaces, leaving no gaps. After application of sealant, bulk fill gaps between floor and underside of plasterboard using Gyproc joint compound.

### **Finish coat**

To achieve the specified performances, the system should be finished using either one of our Thistle or ThistlePro plasters, or Gyproc jointing products. See the product range guides on the British Gypsum website for more information. For further guidance on skimming moisture resistant grade boards see the White Book - Finishes section.


# **Technical Specification**

This document provides guidance on how to achieve performance and warranty requirements by exclusively using British Gypsum products or system specifications.



### GypWall Single Frame A206A281 MR1 (EN)

One layer of Gyproc SoundBloc 15mm one side and one layer of Gyproc SoundBloc MR 15mm the other side of Gypframe 92 AS 50 AcouStuds at 600mm centres. For heights up to 4000mm.



## System performance

Please read performance data with any associated standards.

Fire integrity (mins)	30	Fire insulation (mins)	30
Maximum height (mm)	4000		

The maximum heights quoted are limited by the fire state field of application or by limiting deflection of L/240 at 200 Pa, whichever is the lower of the two.

Sound insulation (Airborne) Rw (dB)	45
Duty rating	Heavy
Partition thickness (mm)	124
Approx. weight (kg/m2)	27

### **Standards**

These standards relate to the above performance data.

BS EN 1364-1, Fire resistance tests for non-loadbearing elements - Walls.

BS 5234-2, Specification for performance requirements for strength and robustness including methods of test.

BS EN ISO 140-3, Acoustics - Measurement of sound insulation in buildings and of building elements. Laboratory measurement of airborne sound insulation of building elements.

### **Further information**

SpecSure® system performance warranty confirms that British Gypsum proprietary systems will perform as specified for the lifetime of the building. The SpecSure® warranty requires that all components are specified in full and constructed in accordance with British Gypsum's installation guidance. For more details see the British Gypsum website. Always check with the design team before making any changes to the chosen specification, ensuring appropriate substantiation is sought to confirm that the solution still meets all required project performances.

#### Technical Support Team | british-gypsum.com

This Technical Specification stipulates all British Gypsum products used within a system. These must be used to achieve the stated performance and the **SpecSure**® system warranty.

This document is provided to customers free and the information shown is subject to the accuracy of the information provided to us when the document was originally requested. The document should therefore be approved by the project design and management authority before use to ensure it meets their specific project requirements. It should also be read in conjunction with current literature available at british-gypsum.com. This document is valid at the time of issue, please check with British Gypsum for the latest version. No duty of care is owed to the recipient or any third party and British Gypsum excludes all liability in respect of the information shown to the fullest extent possible save where death or personal injury is caused due to British Gypsum's negligence or for fraud.