


# Technical Specification

This document provides guidance on how to achieve performance and warranty requirements by exclusively using British Gypsum products or system specifications.

GypWall Twin Frame Audio

## A326019B (A) (EN)

Three layers of Gyproc SoundBloc 15mm fixed to outside faces of two Gyprframe 92 S 10 'C' Stud frameworks with studs at 600mm centres, cross braced using Gyprframe GAB3 Acoustic Braces at 3300mm centres. Three layers of 100mm Isover Cladding Roll 40 and two layers of 100mm stone mineral wool (min. 62kg/m<sup>3</sup>) in the cavity. For heights up to 4200mm.



## Head design

Head channel	<b>Gyprframe 94 FEC 50 Folded Edge Standard Floor &amp; Ceiling Channel</b>
Two rows of Gyprframe channel suitably fixed to soffit at 600mm centres in two lines staggered by 300mm.	
Deflection allowance	Vertical deflection only. To be determined by a Structural Engineer.
Dropped soffit	For principles of deflection head construction refer to detail ST-128-Z1L3-09

## Framework

Stud	<b>Gyprframe 92 S 10 'C' Stud</b>
Stud centres - Max (mm)	600

Two rows of Gyprframe studs arranged in pairs.

Abutments and openings	<b>Gyprframe 92 S 10 'C' Stud</b>
------------------------	-----------------------------------

Two rows of Gyprframe 'C' stud suitably fixed to structure at 600mm centres in two lines staggered by 300mm.

Bracing	<b>Gyprframe GAB3 Acoustic Brace</b>	Bracing Centres - Max (mm)	3300
Bracing fixing	<b>British Gypsum Wafer Head Jack-Point Screws 13mm</b>		

Cross bracing half staggered between adjacent stud pairs and fixed to each stud with two wafer head screws.

Base channel	<b>Gyprframe 94 FEC 50 Folded Edge Standard Floor &amp; Ceiling Channel</b>
--------------	---

Two rows of Gyprframe channel suitably fixed to floor at 600mm centres in two lines staggered by 300mm.

## Insulation

Insulation, Layer 1	<b>100mm stone mineral wool (min. 62kg/m<sup>3</sup>)</b>
Insulation, Layer 2	<b>100mm Isover Cladding Roll 40</b>
Insulation, Layer 3	<b>100mm Isover Cladding Roll 40</b>
Insulation, Layer 4	<b>100mm Isover Cladding Roll 40</b>
Insulation, Layer 5	<b>100mm stone mineral wool (min. 62kg/m<sup>3</sup>)</b>

## Board and fixings

Board side 1, Layer 1	<b>Gyproc SoundBloc 15mm</b>	Screws side 1, Layer 1	<b>British Gypsum Jack-Point Screws 25mm</b>
Board side 1, Layer 2	<b>Gyproc SoundBloc 15mm</b>	Screws side 1, Layer 2	<b>British Gypsum Jack-Point Screws 41mm</b>
Board side 1, Layer 3	<b>Gyproc SoundBloc 15mm</b>	Screws side 1, Layer 3	<b>British Gypsum Jack-Point Screws 60mm</b>
Board side 2, Layer 1	<b>Gyproc SoundBloc 15mm</b>	Screws side 2, Layer 1	<b>British Gypsum Jack-Point Screws 25mm</b>
Board side 2, Layer 2	<b>Gyproc SoundBloc 15mm</b>	Screws side 2, Layer 2	<b>British Gypsum Jack-Point Screws 41mm</b>
Board side 2, Layer 3	<b>Gyproc SoundBloc 15mm</b>	Screws side 2, Layer 3	<b>British Gypsum Jack-Point Screws 60mm</b>

Board layer 1 (inner) and board layer 2, fix securely to Gyprframe metal supports around the perimeter of the board at maximum 300mm centres; Board layer 3 (outer), fix securely to all Gyprframe metal supports around the perimeter of the board and intermediate stud positions at maximum 300mm centres. External corners reduce fixings to 200mm. Drywall screws can be used for fixing boards to metal profiles with a thickness of 0.8mm or less. All joints staggered between layers. Fix working from the centre of each board. Position screws not less than 13mm from cut edges and 10mm from bound edges of boards. Set screw heads flush with plasterboard surface; do not break paper or gypsum core.

Fixing strap	<b>Gyprframe GFS1 Fixing Strap</b>
--------------	------------------------------------

Used to support horizontal board joints in face layer of multiple layer board linings and enable board screw fixing at 300mm centres.

Sealant	<b>Gyproc Sealant</b>
---------	-----------------------

Locate sealant at junctions with adjoining structure and other air paths. Apply as a continuous bead to clean, dry, dust-free surfaces, leaving no gaps. After application of sealant, bulk fill gaps between floor and underside of plasterboard using Gyproc joint compound.

## Finish coat

To achieve the specified performances, the system should be finished using either one of our Thistle or ThistlePro plasters, or Gyproc jointing products. See the product range guides on the British Gypsum website for more information.


# Technical Specification

This document provides guidance on how to achieve performance and warranty requirements by exclusively using British Gypsum products or system specifications.

GypWall Twin Frame Audio

## A326019B (A) (EN)

Three layers of Gyproc SoundBloc 15mm fixed to outside faces of two Gypframe 92 S 10 'C' Stud frameworks with studs at 600mm centres, cross braced using Gypframe GAB3 Acoustic Braces at 3300mm centres. Three layers of 100mm Isover Cladding Roll 40 and two layers of 100mm stone mineral wool (min. 62kg/m<sup>3</sup>) in the cavity. For heights up to 4200mm.



## System performance

Please read performance data with any associated standards.

Fire integrity (mins)	<b>90</b>
Maximum height (mm)	<b>4200</b>

Fire insulation (mins)	<b>90</b>
------------------------	-----------

The maximum heights quoted are limited by the fire state field of application or by limiting deflection of L/240 at 200 Pa, whichever is the lower of the two.

Sound insulation (Airborne) Rw (dB)	<b>80</b>
Duty rating	<b>Severe</b>
Partition thickness (mm)	<b>800</b>
Approx. weight (kg/m <sup>2</sup> )	<b>80</b>

Sound insulation (Airborne) Rw + Ctr (dB)	<b>71</b>
---	-----------

## Standards

These standards relate to the above performance data.

BS EN 1364-1, Fire resistance tests for non-loadbearing elements - Walls.

BS 5234-2, Specification for performance requirements for strength and robustness including methods of test.

BS EN ISO 140-3, Acoustics - Measurement of sound insulation in buildings and of building elements. Laboratory measurement of airborne sound insulation of building elements.

## Further information

**SpecSure®** system performance warranty confirms that British Gypsum proprietary systems will perform as specified for the lifetime of the building. The **SpecSure®** warranty requires that all components are specified in full and constructed in accordance with British Gypsum's installation guidance. For more details see the British Gypsum website. Always check with the design team before making any changes to the chosen specification, ensuring appropriate substantiation is sought to confirm that the solution still meets all required project performances.