Technical Specification

This document provides guidance on how to achieve performance and warranty requirements by exclusively using British Gypsum products or system specifications.

GypLyner Independent

B216005 (B) (EN)

Two layers of Gyproc SoundBloc 12.5mm to one side of Gypframe 60 I 50 'I' Stud framework with 50mm Isover Steel Frame Infill Batts between studs forming an independent lining to structural steel columns, in association with external steel cladding (0.6mm). For heights up to 3000mm.



Background

Background	Steel Clad External Wall

Head design

Head channel	**Gypframe 62 FEC 50 Folded Edge Standard Floor & Ceiling Channel**

Gypframe channel suitably fixed to soffit at 600mm centres.

Deflection allowance	Vertical deflection only. To be determined by a Structural Engineer.

Framework

Stud	**Gypframe 60 I 50 'I' Stud**
Stud centres - Max (mm)	600
Abutments and openings	**Gypframe 60 S 50 'C' Stud**

Gypframe 'C' stud suitably fixed to structure at 600mm centres.

Base channel	**Gypframe 62 FEC 50 Folded Edge Standard Floor & Ceiling Channel**

Gypframe channel suitably fixed to floor at 600mm centres.

Insulation

Insulation, Layer 1	**50mm Isover Steel Frame Infill Batt**

Board and fixings

Board side 1, Layer 1	**Gyproc SoundBloc 12.5mm**	Screws side 1, Layer 1	**British Gypsum Drywall Screws 25mm**
Board side 1, Layer 2	**Gyproc SoundBloc 12.5mm**	Screws side 1, Layer 2	**British Gypsum Drywall Screws 35mm**

Board layer 1 (inner), fix securely to Gypframe metal supports around the perimeter of the board at maximum 300mm centres; Board layer 2 (outer), fix securely to all Gypframe metal supports around the perimeter of the board and intermediate stud positions at maximum 300mm centres. External corners reduce fixings to 200mm. All joints staggered between layers. Fix working from the centre of each board. Position screws not less than 13mm from cut edges and 10mm from bound edges of boards. Set screw heads flush with plasterboard surface; do not break paper or gypsum core.

Fixing strap	**Gypframe GFS1 Fixing Strap**

Used to support horizontal board joints in face layer of multiple layer board linings and enable board screw fixing at 300mm centres.

Sealant	**Gyproc Sealant**

Locate sealant at junctions with adjoining structure and other air paths. Apply as a continuous bead to clean, dry, dust-free surfaces, leaving no gaps. After application of sealant, bulk fill gaps between floor and underside of plasterboard using Gyproc jointing compound.

Finish coat

To achieve the specified performances, the system should be finished using either one of our Thistle or ThistlePro plasters, or Gyproc jointing products. See the product range guides on the British Gypsum website for more information.

Technical Specification

This document provides guidance on how to achieve performance and warranty requirements by exclusively using British Gypsum products or system specifications.

GypLyner Independent

B216005 (B) (EN)

Two layers of Gyproc SoundBloc 12.5mm to one side of Gypframe 60 I 50 'I' Stud framework with 50mm Isover Steel Frame Infill Batts between studs forming an independent lining to structural steel columns, in association with external steel cladding (0.6mm). For heights up to 3000mm.



System performance

Please read performance data with any associated standards.

Fire integrity (mins)	**30**
Maximum height (mm)	**3000**

Fire insulation (mins)	**30**

The maximum heights quoted are limited by the fire state field of application or by limiting deflection of L/240 at 200 Pa, whichever is the lower of the two.

Duty rating	**Severe**
Minimum cavity / offset (mm)	**30**
Approx. weight (kg/m2)	**26**

Standards

These standards relate to the above performance data.

BS 5234-2, Specification for performance requirements for strength and robustness including methods of test.

BS EN 1364-1, Fire resistance tests for non-loadbearing elements - Walls.

Further information

SpecSure® system performance warranty confirms that British Gypsum proprietary systems will perform as specified for the lifetime of the building. The **SpecSure**® warranty requires that all components are specified in full and constructed in accordance with British Gypsum's installation guidance. For more details see the British Gypsum website. Always check with the design team before making any changes to the chosen specification, ensuring appropriate substantiation is sought to confirm that the solution still meets all required project performances.

This document is provided to customers free and the information shown is subject to the accuracy of the information provided to us when the document was originally requested. The document should therefore be approved by the project design and management authority before use to ensure it meets their specific project requirements. It should also be read in conjunction with current literature available at british-gypsum.com. This document is valid at the time of issue, please check with British Gypsum for the latest version. No duty of care is owed to the recipient or any third party and British Gypsum excludes all liability in respect of the information shown to the fullest extent possible save where death or personal injury is caused due to British Gypsum's negligence or for fraud.