Technical Specification


This document provides guidance on how to achieve performance and warranty requirements by exclusively using British Gypsum products or system specifications.

GypLyner Independent

GIWL 146 I 80 PIR (B) (EN)

One layer of Gyproc ThermaLine PIR 38mm to one side of Gypframe 146 I 80 'I' Stud framework forming an independent lining to masonry background. For heights up to 6900mm.





Background

| Background | Masonry |
|------------|---------|

Head design

| Head channel | Gypframe 148 DC 60 Deep Flange Floor & Ceiling Channel |
|---|---|
| Gypframe channel suitably fixed to soffit at 600mm centres in two lines staggered by 300mm. | |
| Deflection allowance | Vertical deflection only. To be determined by a Structural Engineer. |
| Dropped soffit | For principles of deflection head construction refer to detail ST-224-Z2LA-06 |

Framework

| Stud | Gypframe 146 I 80 'I' Stud |
|-------------------------|----------------------------|
| Stud centres - Max (mm) | 600 |
| Abutments and openings | Gypframe 146 S 50 'C' Stud |

Gypframe 'C' stud suitably fixed to structure at 600mm centres in two lines staggered by 300mm.

| Base channel Gypframe 148 DC 60 Deep Flange Floor & Ceiling Channel | |
|---|--|
|---|--|

Gypframe channel suitably fixed to floor at 600mm centres in two lines staggered by 300mm.

Insulation

No insulation

Board and fixings

| | Board side 1, Layer 1 | Gyproc ThermaLine PIR 38mm | Screws side 1, Layer 1 | British Gypsum Jack-Point Screws 60mm |
|---|-----------------------------------|--|-------------------------------|--|
| | Board layer 1, fix securely to Gy | pframe metal supports around the perimeter of the boa | ard and intermediate stud pos | itions at maximum 300mm centres. External corners reduce |
| 1 | fixings to 200mm. Drywall screw | s can be used for fixing boards to metal profiles with a | thickness of 0.8mm or less (| excluding 'I' studs). Fix working from the centre of each board. |
| | Position screws not less than 13 | 8mm from cut edges and 10mm from bound edges of b | oards. Set screw heads flush | with plasterboard surface; do not break paper or gypsum core. |

| Fixing strap Gypframe GFS1 | I Fixing Strap | |
|----------------------------|----------------|--|
|----------------------------|----------------|--|

Used to support horizontal board joints and enable board screw fixing at 300mm centres.

| Fixing T | Gynframe GFT1 Fixing 'T' |
|----------|--------------------------|

Used to support horizontal board joints and enable board screw fixing at 300mm centres.

Sealant Gyproc Sealant

Locate sealant at junctions with adjoining structure and other air paths. Apply as a continuous bead to clean, dry, dust-free surfaces, leaving no gaps. After application of sealant, bulk fill gaps between floor and underside of plasterboard using Gyproc jointing compound.

Finish coat

The system should be finished using either one of our Thistle or ThistlePro plasters, or Gyproc jointing products. See the product range guides on the British Gypsum website for more information.

Technical Specification

This document provides guidance on how to achieve performance and warranty requirements by exclusively using British Gypsum products or system specifications.

GypLyner Independent

GIWL 146 I 80 PIR (B) (EN)

One layer of Gyproc ThermaLine PIR 38mm to one side of Gypframe 146 I 80 'I' Stud framework forming an independent lining to masonry background. For heights up to 6900mm.





System performance

Please read performance data with any associated standards.

| Maximum height (mm) | 6900 |
|---|----------------------|
| The maximum heights quoted are based upon a limiting deflection | on of L/240 at 200 F |
| Minimum cavity / offset (mm) | 30 |

The minimum cavity/offset is recommended to avoid bridging between the background and metal studs over the lining system height.

Further information

SpecSure® system performance warranty confirms that British Gypsum proprietary systems will perform as specified for the lifetime of the building. The **SpecSure®** warranty requires that all components are specified in full and constructed in accordance with British Gypsum's installation guidance. For more details see the British Gypsum website. Always check with the design team before making any changes to the chosen specification, ensuring appropriate substantiation is sought to confirm that the solution still meets all required project performances.

This Technical Specification stipulates all British Gypsum products used within a system. These must be used to achieve the stated performance and the **SpecSure**® system warranty.

This document is provided to customers free and the information shown is subject to the accuracy of the information provided to us when the document was originally requested. The document should therefore be approved by the project design and management authority before use to ensure it meets their specific project requirements. It should also be read in conjunction with current literature available at british-gypsum.com. This document is valid at the time of issue, please check with British Gypsum for the latest version. No duty of care is owed to the recipient or any third party and British Gypsum excludes all liability in respect of the information shown to the fullest extent possible save where death or personal injury is caused due to British Gypsum's negligence or for fraud.