

LETTER OF CONFORMITY

Introduction

Thistle MultiFinish is a gypsum finish plaster for use on a wide range of backgrounds. It provides a smooth, inert, high quality surface to internal walls and a durable base for the application of decorative finishes.

This letter of conformity substantiates the airborne sound insulation performance for the system described below when a nominally 2mm-thick layer of Thistle MultiFinish is applied to both sides of the partition.

System reference: Q606063S

System description: Gypframe 70S50 'C' Studs at 600mm centres lined with a single layer of 15mm Gyproc DuraLine and 25mm Isover Acoustic Partition Roll in the cavity.

From an extensive body of test evidence and experience in acoustic testing, the effect of applying a 2mm-thick layer of Thistle MultiFinish on the acoustic performance of the system can be estimated. The test evidence shows the magnitude of the effect of applying Thistle MultiFinish depends on the sound insulation spectral shape of the un-skimmed partition. By analysing the distribution of the adverse deviation compared to the rating curve the method derived shows that the effect of applying skim on the Rw rating can range from 0 to + 2dB.

The airborne sound insulation performance of the un-skimmed partition, Rw 47dB

The estimated airborne sound insulation performance of the skimmed partition, Rw is 48dB.

This letter is issued on the basis of test data and information to hand at the time of issue. If contradictory evidence becomes available to British Gypsum then the letter will be unconditionally withdrawn. Similarly, the letter is invalidated if the proposed construction is subsequently tested since actual test data is deemed to take precedence over an expressed opinion.

Issued by:

Robert Evans
MEng Hons.

Date: 6th November 2018