


Standard Detail

This drawing provides general guidance where no performance criteria is given and site specific conditions are not taken into account


GypCeiling Grid

- 1 CasoLine Quick-Lock Grid Main Tee at 1200mm centres
- 2 CasoLine Quick-Lock Grid Cross Tee 1200mm length at 600mm centres
- 3 CasoLine Quick-Lock Grid Cross Tee 600mm length at 1200mm centres
- 4 CasoLine Quick-Lock Grid Wall Angle suitably fixed to wall/batten at 300mm centres
- 5 CasoLine Quick-Lock Grid Hanger or suspension wire (14 SWG) by others at 1200mm centres
- 6 Gypframe MF12 Soffit Cleat suitably fixed to soffit
- 7 Gypsum tiles with edge profile E
- 8 Timber batten suitably fixed to wall
- 9 Suitable size teg block with self adhesive top by others fixed to underside of tee section



Perimeter option 1

Perimeter option 2



Layout

600 x 600mm module

Rev. A 11.10.23 Perimeter component changed (MRC)

Title: GypCeiling Grid
Tile edge profile E
Standard details read with project specification

Scale at A4: 1:5
Date: October 2021
Dwg No.: ST-326-ZZEE-01

Drawn: MRC
Approved: MBH
Revision: A

Technical Support Team | british-gypsum.com


This drawing is provided to customers free of charge and the details shown are subject to the accuracy of the information provided to British Gypsum at the time the drawing was originally requested. The drawing should therefore be approved by the project design and management authority before use to ensure that it meets with their specific project requirements. It should also be read in conjunction with British Gypsum's current literature available at www.british-gypsum.com. Taping and finishing in accordance with British Gypsum's current recommendations is assumed (with the exception of FireCase system). Please note the drawing may show British Gypsum products fixed by or to products that are non-British Gypsum products/fixings please refer to Specifying Authority for specification details. This drawing is valid at the time of issue, please check with British Gypsum for the latest version. No duty of care is owed to the recipient or any third party and British Gypsum excludes all liability in respect of the details shown save where death or personal injury is caused due to British Gypsum's negligence or for fraud.

Standard Detail

This drawing provides general guidance where no performance criteria is given and site specific conditions are not taken into account


GypCeiling Grid

- 1 CasoLine Quick-Lock Grid
- 2 CasoLine Quick-Lock Grid Wall Angle fixed to MF6 with suitable British Gypsum wafer head screws
- 3 Gypsum tiles with edge profile E
- 4 One layer Gyproc plasterboard or Glasroc specialist board fixed with suitable British Gypsum screws at 230mm centres in field of board and 150mm centres at board ends
- 5 Gyframe MF5 Ceiling Sections at max. 450mm centres fixed to each MF7 with two suitable British Gypsum wafer head screws or MF9 Connecting Clip
- 6 Gyframe MF6 Perimeter Channel suitably fixed to wall at 600mm centres
- 7 Gyframe MF6 Perimeter Channel fixed to each MF5/MF7 with suitable British Gypsum wafer head screws
- 8 Gyframe MF7 Primary Support Channels at 1200mm centres
- 9 Gyframe MF8 Strap Hanger or FEA1 Steel Angle hangers at 1200mm centres fixed to MF7 with two suitable British Gypsum wafer head screws
- 10 Gyframe MF12 Soffit Cleat fixed to hanger with MF11 Nut and Bolt and suitably fixed to soffit
- 11 Gyframe MF12 Soffit Cleat fixed to MF7 with MF11 Nut and Bolt and suitably fixed to wall (not required if min. two hangers used)
- 12 Suitable size teg block with self adhesive top by others fixed to underside of tee section



Plasterboard ceiling junction 1

MF5 parallel to wall



Plasterboard ceiling junction 2

MF5 perpendicular to wall

Rev. A 11.10.23 Perimeter component changed (MRC)

Title: GypCeiling Grid
Tile edge profile E
Standard details read with project specification

Scale at A4: 1:5
Date: October 2021
Dwg No.: ST-326-ZZEE-02

Drawn: MRC
Approved: MBH
Revision: A


Technical Support Team | british-gypsum.com

This drawing is provided to customers free of charge and the details shown are subject to the accuracy of the information provided to British Gypsum at the time the drawing was originally requested. The drawing should therefore be approved by the project design and management authority before use to ensure that it meets with their specific project requirements. It should also be read in conjunction with British Gypsum's current literature available at www.british-gypsum.com. Taping and finishing in accordance with British Gypsum's current recommendations is assumed (with the exception of FireCase system). Please note the drawing may show British Gypsum products fixed by or to products that are non-British Gypsum products/fixings please refer to Specifying Authority for specification details. This drawing is valid at the time of issue, please check with British Gypsum for the latest version. No duty of care is owed to the recipient or any third party and British Gypsum excludes all liability in respect of the details shown save where death or personal injury is caused due to British Gypsum's negligence or for fraud.


British Gypsum
SAINT-GOBAIN

SAINT-GOBAIN

1	CasoLine Quick-Lock Grid	8	Gypframe MF7 Primary Support Channels at 1200mm centres
2	CasoLine Quick-Lock Grid Wall Angle fixed through plasterboard to GA4 with suitable British Gypsum screws at 300mm centres	9	Gypframe MF8 Strap Hanger or FEA1 Steel Angle hangers at 1200mm centres fixed to MF7 with two suitable British Gypsum wafer head screws
3	Gypsum tiles with edge profile E	10	Gypframe MF12 Soffit Cleat fixed to hanger with MF11 Nut and Bolt and suitably fixed to soffit
4	One layer Gyproc plasterboard or Glasroc specialist board fixed with suitable British Gypsum screws at 230mm centres in field of board and 150mm centres at board ends	11	Gypframe MF12 Soffit Cleat fixed to MF7 with MF11 Nut and Bolt and suitably fixed to wall (not required if min. two hangers used)
5	Gypframe MF5 Ceiling Sections at max. 450mm centres fixed to each MF7 with two suitable British Gypsum wafer head screws or MF9 Connecting Clip	12	Gypframe GA4 Steel Angle fixed to each MF7 with suitable British Gypsum wafer head screws
6	Gypframe MF6 Perimeter Channel suitably fixed to wall at 600mm centres	13	Gypframe GA4 Steel Angle fixed to MF6 with suitable British Gypsum wafer head screws at 600mm centres
7	Gypframe MF6 Perimeter Channel fixed to each MF5/MF7 with suitable British Gypsum wafer head screws	14	Suitable size teg block with self adhesive top by others fixed to underside of tee section



MF5 parallel to wall



MF5 perpendicular to wall

Drawn: MRC
Approved: MBH
Revision: A

This drawing is provided to customers free of charge and the details shown are subject to the accuracy of the information provided to British Gypsum at the time the drawing was originally requested. The drawing should therefore be approved by the project design and management team before use to ensure that it meets with their specific project requirements. It should also be read in conjunction with British Gypsum's current literature available at www.british-gypsum.com. Taping and finishing in accordance with British Gypsum's current recommendations is assumed (with the exception of FireCase systems). Please note the drawing may show British Gypsum products fixed by or to products that are non-British Gypsum products/things please refer to Specifying Authority for specification details. This drawing is valid at the time of issue, please check with British Gypsum for the latest version. No duty of care is owed by the recipient of, nor third party and British Gypsum excludes all liability in respect of the details shown save where death or personal injury is caused due to British Gypsum's negligence or for fraud.