

CERTIFICATE OF CONSTANCY OF PERFORMANCE

This is to certify that UL International (UK) Ltd. did undertake the relevant AVCP procedures for the equipment identified below which was found to be in compliance with the Construction Products Regulation 2011 as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, subject to any conditions attached hereto.

Certificate No.
0843-CPR-1438

Issue date
18-06-2025

Issue No.
1

Re-Issue date
N/A



4705

Manufacturer:

Saint-Gobain Construction Products UK Ltd t/a British Gypsum

Address:

Saint-Gobain House,
East Leake, Loughborough,
Leicestershire, LE12 6JU

Product:

Gyproc Acrylic Fire Sealant

Places of production:

A/003

Harmonized requirements

EAD 350454-00-1104; September 2017 & EAD 350141-00-1106,
September 2017

Scope of Certificate

0843-UKTA-25/0019 issued on 30/05/2025 &
0843-UKTA-25/0020 issued on 30/05/2025

On behalf of the Head of Approved Body:

A handwritten signature in blue ink, appearing to read 'Chris Johnson'.

Chris Johnson

Issued by UL International (UK) Ltd, Approved Body 0843.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in 0843-UKTA-25/0019 & 0843-UKTA-25/0020 of the above referenced standards, under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate will remain valid as long as neither the EAD, 0843-UKTA-25/0019 & 0843-UKTA-25/0020, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the UK Approved body.



Solutions

Form-ULID-006104 V8.0

Detailed information sheet:

Product Reference:	Gyproc Acrylic Fire Sealant
Type:	Firestop – Sealant used as a penetration seal and linear joint seal
Description:	A sealant used to form a penetration seal around metallic pipes, plastic pipes, composite pipes, combustible cable conduits and electrical cables to reinstate the fire resistance performance of wall and floor constructions, where they have been provided with apertures for the penetration of services. The sealant can also be used to form linear gap seals where gaps are present in wall and floor constructions and linear joint seals where wall and floor constructions abut. Gyproc Acrylic Fire Sealant is supplied in liquid form contained within 310 & 380ml cartridges and 600ml foil packs. The sealant is gunned into the aperture in the separating element/ elements and around the service or services, to a specified depth utilising a backing material.
Key Performance parameters:	See 0843-UKTA-25/0019 & 0843-UKTA-25/0020
Identification and intended use	See Product Label



Limitations on the acceptance or use of the product(s):

Installation instructions	To be used in accordance with the supplier's installation instructions, technical datasheet and UKTA.
Limitations	See Technical Data Sheet and the UKTA
UL Report:	4791660665

Terms and Conditions:

1. This certificate remains the property of UL International (UK) Ltd, herein "UL UK", and will be withdrawn if any conditions attached to its issue are not complied with.
2. This certificate is issued subject to the Global Services Agreement (GSA) and UKCA CPR Service Terms.
3. Production is limited to the site(s) as listed, or detailed within the Technical documentation held by UL UK.
4. Any product change, production/process changes, etc. which may affect conformity shall be notified to UL UK.
5. This certificate is only valid for placing goods on the market of United Kingdom excluding Northern Ireland.

END OF CERTIFICATE

