
Technical Specification

This document provides guidance on how to achieve performance and warranty requirements by exclusively using British Gypsum products or system specifications.

British Gypsum

GypWall Single Frame A206261 MR2 (EN)

One layer of Gyproc SoundBloc MR 15mm each side of Gypframe 92 S 50 $^{\prime}C^{\prime}$ Studs at 600mm centres. For heights up to 4000mm.



Head design

| Head channel | Gypframe 94 FEC 50 Folded Edge Standard Floor & Ceiling Channel | | | |
|---|--|--|--|--|
| Gypframe channel suitably fixed to soffit at 600mm centres in two lines staggered by 300mm. | | | | |
| Deflection allowance | Vertical deflection only. To be determined by a Structural Engineer. | | | |
| Dropped soffit | For principles of deflection head construction refer to detail ST-121-Z1L1-08. | | | |

Framework

| Stud | Gypframe 92 S 50 'C' Stud | | | |
|---|---|--|--|--|
| Stud centres - Max (mm) | 600 | | | |
| Abutments and openings | Gypframe 92 S 50 'C' Stud | | | |
| Gypframe 'C' stud suitably fixed to structure at 600mm centres in two lines staggered by 300mm. | | | | |
| Base channel | Gypframe 94 FEC 50 Folded Edge Standard Floor & Ceiling Channel | | | |

Gypframe channel suitably fixed to floor at 600mm centres in two lines staggered by 300mm.

Insulation

No insulation

Board and fixings

| Board side 1, Layer 1 | Gyproc SoundBloc MR 15mm | Screws side 1, Layer 1 | British Gypsum Drywall Screws 25mm | | | | |
|---|--|------------------------|------------------------------------|--|--|--|--|
| Board side 2, Layer 1 | Gyproc SoundBloc MR 15mm | Screws side 2, Layer 1 | British Gypsum Drywall Screws 25mm | | | | |
| Board layer 1, fix securely to Gypframe metal supports around the perimeter of the board and intermediate stud positions at maximum 300mm centres. External corners reduce fixings to 200mm. All joints staggered between layers. Fix working from the centre of each board. Position screws not less than 13mm from cut edges and 10mm from bound edges of boards. Set screw heads flush with plasterboard surface; do not break paper or gypsum core. | | | | | | | |
| Fixing strap | Gypframe GFS1 Fixing Strap | | | | | | |
| Used to support horizontal boa | rd joints and enable board screw fixing at 300mm | centres. | | | | | |
| Fixing T | Gypframe GFT1 Fixing 'T' | | | | | | |
| Used to support horizontal boa | rd joints and enable board screw fixing at 300mm | centres. | | | | | |
| Sealant | Gyproc Sealant | | | | | | |

Sealant Gyproc Sealant

Locate sealant at junctions with adjoining structure and other air paths. Apply as a continuous bead to clean, dry, dust-free surfaces, leaving no gaps. After application of sealant, bulk fill gaps between floor and underside of plasterboard using Gyproc joint compound.

Finish coat

To achieve the specified performances, the system should be finished using either one of our Thistle or ThistlePro plasters, or Gyproc jointing products. See the product range guides on the British Gypsum website for more information. For further guidance on skimming moisture resistant grade boards see the White Book - Finishes section.


Technical Specification

This document provides guidance on how to achieve performance and warranty requirements by exclusively using British Gypsum products or system specifications.



GypWall Single Frame A206261 MR2 (EN)

One layer of Gyproc SoundBloc MR 15mm each side of Gypframe 92 S 50 'C' Studs at 600mm centres. For heights up to 4000mm.



System performance

Please read performance data with any associated standards.

| Fire integrity (mins) | 30 | Fire insulation (mins) | 30 |
|-----------------------|------|------------------------|----|
| Maximum height (mm) | 4000 | | |

The maximum heights quoted are limited by the fire state field of application or by limiting deflection of L/240 at 200 Pa, whichever is the lower of the two.

| Sound insulation (Airborne) Rw (dB) | 44 |
|-------------------------------------|-------|
| Duty rating | Heavy |
| Partition thickness (mm) | 124 |
| Approx. weight (kg/m2) | 27 |

Standards

These standards relate to the above performance data.

BS EN 1364-1, Fire resistance tests for non-loadbearing elements - Walls.

BS 5234-2, Specification for performance requirements for strength and robustness including methods of test.

BS EN ISO 140-3, Acoustics - Measurement of sound insulation in buildings and of building elements. Laboratory measurement of airborne sound insulation of building elements.

Further information

SpecSure® system performance warranty confirms that British Gypsum proprietary systems will perform as specified for the lifetime of the building. The SpecSure® warranty requires that all components are specified in full and constructed in accordance with British Gypsum's installation guidance. For more details see the British Gypsum website. Always check with the design team before making any changes to the chosen specification, ensuring appropriate substantiation is sought to confirm that the solution still meets all required project performances.

Technical Support Team | british-gypsum.com

This Technical Specification stipulates all British Gypsum products used within a system. These must be used to achieve the stated performance and the **SpecSure**® system warranty.

This document is provided to customers free and the information shown is subject to the accuracy of the information provided to us when the document was originally requested. The document should therefore be approved by the project design and management authority before use to ensure it meets their specific project requirements. It should also be read in conjunction with current literature available at british-gypsum.com. This document is valid at the time of issue, please check with British Gypsum for the latest version. No duty of care is owed to the recipient or any third party and British Gypsum excludes all liability in respect of the information shown to the fullest extent possible save where death or personal injury is caused due to British Gypsum's negligence or for fraud.