Technical Specification


This document provides guidance on how to achieve performance and warranty requirements by exclusively using British Gypsum products or system specifications.

GypWall Resilient

A316013 (EN)

Two layers of Gyproc SoundBloc 15mm each side of Gypframe 70 S 50 'C' Studs at 600mm centres with Gypframe RB1 Resilient Bar at 600mm centres to both sides. 50mm Isover Acoustic Partition Roll (APR 1200) in the cavity. For heights up to 3200mm.





Head design

Head channel Gypframe 72 FEC 50 Folded Edge Standard Floor & Ceiling Channel Gypframe channel suitably fixed to soffit at 600mm centres.	
Dropped soffit	For principles of deflection head construction refer to detail ST-124-Z5L2-09.

Framework

Stud	Gypframe 70 S 50 'C' Stud
Stud centres - Max (mm)	600
Abutments and openings	Gypframe 70 S 50 'C' Stud
0	-tt

Gypframe 'C' stud suitably fixed to structure at 600mm centres.

Gypframe RB1 Resilient Bar
Gypframe RB1 Resilient Bar
600
British Gypsum Wafer Head Drywall Screws 13mm

Horizontal resilient bars and short lengths of resilient bar (between horizontal bars at perimeters) fixed using wafer head screws.

Base channel	Gypframe 72 FEC 50 Folded Edge Standard Floor & Ceiling Channel
Base channel	Gypframe 72 FEC 50 Folded Edge Standard Floor & Ceiling Channel

Gypframe channel suitably fixed to floor at 600mm centres.

Insulation

Insulation, Layer 1	50mm Isover Acoustic Partition Roll (APR 1200)

Board and fixings

Board side 1, Layer 1	Gyproc SoundBloc 15mm	Screws side 1, Layer 1	British Gypsum Drywall Screws 25mm
Board side 1, Layer 2	Gyproc SoundBloc 15mm	Screws side 1, Layer 2	British Gypsum Drywall Screws 40mm
Board side 2, Layer 1	Gyproc SoundBloc 15mm	Screws side 2, Layer 1	British Gypsum Drywall Screws 25mm
Board side 2, Layer 2	Gyproc SoundBloc 15mm	Screws side 2, Layer 2	British Gypsum Drywall Screws 40mm

Board layer 1 (inner), fix securely to Gypframe Resilient Bars around the perimeter of the board at maximum 300mm centres; Board layer 2 (outer), fix securely to all Gypframe Resilient Bars around the perimeter of the board and within the field of the board at maximum 300mm centres. External corners reduce fixings to 200mm. All joints staggered between layers. Fix working from the centre of each board. Position screws not less than 13mm from cut edges and 10mm from bound edges of boards. Set screw heads flush with plasterboard surface; do not break paper or gypsum core

Sealant	Gyproc Sealant

Locate sealant at junctions with adjoining structure and other air paths. Apply as a continuous bead to clean, dry, dust-free surfaces, leaving no gaps. After application of sealant, bulk fill gaps between floor and underside of plasterboard using Gyproc joint compound.

Finish coat

To achieve the specified performances, the system should be finished using either one of our Thistle or ThistlePro plasters, or Gyproc jointing products. See the product range guides on the British Gypsum website for more information.

Technical Specification


This document provides guidance on how to achieve performance and warranty requirements by exclusively using British Gypsum products or system specifications.



GypWall Resilient

A316013 (EN)

Two layers of Gyproc SoundBloc 15mm each side of Gypframe 70 S 50 'C' Studs at 600mm centres with Gypframe RB1 Resilient Bar at 600mm centres to both sides. 50mm Isover Acoustic Partition Roll (APR 1200) in the cavity. For heights up to 3200mm.



System performance

Please read performance data with any associated standards.

Fire integrity (mins)	90
Maximum height (mm)	3200

Fire insulation (mins)	90

The maximum heights quoted are limited by the fire state field of application or by limiting deflection of L/240 at 200 Pa, whichever is the lower of the two.

Sound insulation (Airborne) Rw (dB)	65
Duty rating	Severe
Partition thickness (mm)	162
Approx. weight (kg/m2)	51

	Sound insulation (Airborne) Rw + Ctr (dB)	57
--	---	----

Standards

These standards relate to the above performance data.

BS EN 1364-1, Fire resistance tests for non-loadbearing elements - Walls.

BS 5234-2, Specification for performance requirements for strength and robustness including methods of test.

BS EN ISO 140-3, Acoustics - Measurement of sound insulation in buildings and of building elements. Laboratory measurement of airborne sound insulation of building elements.

Further information

SpecSure® system performance warranty confirms that British Gypsum proprietary systems will perform as specified for the lifetime of the building. The **SpecSure**® warranty requires that all components are specified in full and constructed in accordance with British Gypsum's installation guidance. For more details see the British Gypsum website. Always check with the design team before making any changes to the chosen specification, ensuring appropriate substantiation is sought to confirm that the solution still meets all required project performances.

This Technical Specification stipulates all British Gypsum products used within a system. These must be used to achieve the stated performance and the **SpecSure®** system warranty.